

CITY OF LOMITA



TO OUR CUSTOMERS

Each year, the City of Lomita provides this report to inform you, our customers, about the quality of the water you drink. We are proud to report that in 2013, your water met or surpassed all health-based drinking water standards.

In order to ensure that tap water is safe to drink, the U.S. Environmental Protection Agency (USEPA) and the California Department of Public Health (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

To meet these regulations, the City of Lomita contracts with the Los Angeles County Waterworks Districts to oversee water quality monitoring and reporting. We welcome your thoughts and suggestions to improve our service and delivery of the earth's most precious resource. Please visit our website, www.lomita.com/cityhall, or attend our City Council meetings. They are typically held the first and third Monday of each month at 7 p.m. and are held in Lomita City Hall.

Thank you for taking the time to read our annual water quality report. We look forward to another year of providing you with safe, reliable water.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.



ANNUAL WATER QUALITY REPORT

Water testing performed in 2013



SOURCES OF WATER

The Metropolitan Water District of Southern California (MWD) is a consortium of 26 cities and water districts that provides drinking water to nearly 19 million people in parts of Los Angeles, Orange, San Diego, Riverside, San Bernardino and Ventura counties. MWD supplies the City of Lomita with water treated at the Weymouth Treatment Plant. Most of the water treated at this plant originates in the mountain ranges in seven western states, travels down the Colorado River and flows through MWD's 242-mile Colorado River Aqueduct. To a lesser degree, water supplied to the plant also comes from Northern California rivers and streams that feed the State Water Project's 444-mile California Aqueduct.

The plant uses conventional techniques to treat your water. This includes the coagulation process where aluminum sulfate and other chemical additives cling to particles in the water. These particles stick together and form large particles that will settle to the bottom of large sedimentation basins. Then, the water flows through coal and sand for filtration. Chloramines (chlorine plus ammonia) disinfection is used to kill remaining microorganisms, such as bacteria, and to keep the water safe as it travels to your tap. The water received from the MWD is then mixed with the City of Lomita's groundwater well located in the service area.

In December 2002, MWD completed a source water assessment of its Colorado River and State Water Project supplies. Colorado River water is considered to be most vulnerable to recreation, urban and storm water runoff, increasing urbanization in the watershed, and wastewater. The State Water Project is considered to be most vulnerable to urban and storm water runoff, wildlife, agriculture, recreation, and wastewater. A copy of the assessment can be obtained by contacting Metropolitan Water District at (213) 217-6850.

An assessment of the City's groundwater well assessment was completed in 2014. The well is considered vulnerable to various contaminating activities including the following: landfills/dumps, automobile-repairs, gas stations, dry cleaners and other chemical/industrial activities. A copy of the complete assessment may be viewed at: California Department of Public Health Los Angeles Office, 500 North Central Avenue, Suite 500, Glendale CA 91203 or by phone at (818)551-2004.

PUBLIC PARTICIPATION AND CONTACT INFORMATION

Regular City Council Meetings are held on the first and third Mondays of each month at 7 p.m. in Lomita City Hall located at 24300 Narbonne Avenue, City of Lomita CA 90717.

For questions or comments regarding water quality or this report, please contact the City of Lomita Public Works Department at (310) 325-9830. To view this report on the internet, please visit the Los Angeles County Waterworks District website at www.lacwaterworks.org.



DRINKING WATER & YOUR HEALTH

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. Environmental Protection Agency's (USEPA) Safe Drinking Water Hotline (1-800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- * Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- * Inorganic contaminants, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- * Pesticides and herbicides, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- * Organic chemical contaminants, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- * Radioactive contaminants, that can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

WATER CONSERVATION TIPS

In addition to protecting the quality of water delivered to you, we also promote and implement water conservation programs for the Districts' customers. For tips on how to conserve water and to learn more about the programs we offer, visit www.lacwaterworks.org or contact Rea Gonzalez at (626) 300-3338. We can all take these simple steps to conserve water:

Indoor

- * Fix indoor faucet and toilet leaks. Just a drip can waste more than 10,000 gallons per month.
- * Turn off the water while you brush your teeth or shave.
- * Take shorter showers and install a water efficient showerhead.
- * Wash only full loads in the dishwasher and washing machine.

Outdoor

- * Water according to current weather and season.
- * Adjust your sprinkler heads so they water the yard, not the sidewalk or street.
- * Landscape your yard and garden with California native and drought-tolerant plants. These plants are accustomed to local weather and soil conditions and thrive with little summer watering. Using them not only saves water, but also saves maintenance time and produces a habitat for native birds, beneficial insects and wildlife. The best time to plant native plants is between October and May each year.



LEAD & COPPER

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.



SAMPLING RESULTS

During the past year, your water is tested for chemical, physical, radiological and bacteriological parameters. We also test for additional organic and inorganic chemicals that are not regulated. The tables included in this report list all the substances that were detected. The presence of these substances in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table are from the testing performed last year. The State allows us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

Table Definitions

90th Percentile: Out of every 10 homes sampled, 9 were at or below this level.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standard (PDWS): MCLs and MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

ppb: parts per billion (micrograms per liter)
ppm: parts per million (milligrams per liter)
µS/cm: MicroSiemens per centimeter
NTU: Nephelometric turbidity unit
TON: Threshold Odor Number

N/A: Not applicable
ND: Non-detect
NL: Notification level
pCi/L: PicoCuries per liter

** HAA5, chlorine, TTHMs, color, odor, turbidity and pH were measured within the distribution system

** Iron and Manganese were measured after treatment at the entry point to distribution system

PRIMARY DRINKING WATER STANDARDS							
SUBSTANCE (UNIT OF MEASURE)	MCL [MRDL]	PHG [MCLG]	GROUNDWATER & DISTRIBUTION		MWD		TYPICAL SOURCE
			RANGE	DETECTED AVERAGE LEVEL (2013)	RANGE	DETECTED AVERAGE LEVEL (2013)	
Aluminum (ppm)	1	0.6	N/A	ND	0.095 - 0.220	0.14	Erosion of natural deposits; residue from some surface water treatment processes
Chlorine (ppm)*	[4.0] as Cl ₂	MRDLG = 4 as Cl ₂	ND - 3.9	2.13	N/A	N/A	Drinking water disinfectant added for treatment
Combined radium (pCi/L)	5	0	N/A	0.128	ND	ND	Erosion of natural deposits
Copper (ppm)	AL = 1.3	0.3	N/A	0.07	ND	ND	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Fluoride (ppm)	2.0	1	N/A	0.336	0.7 - 1.0	0.8	Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories
Gross Alpha Particle Activity (pCi/L)	15	[0]	N/A	3.96	ND - 3	ND	Erosion of natural deposits
Gross Beta Particle Activity (pCi/L)	50	[0]	N/A	N/A	ND - 6	4	Decay of natural and man-made deposits
Haloacetic Acids [HAA5] (ppb)*	60	N/A	1.5 - 24	17.18	N/A	N/A	Byproduct of drinking water disinfection
Total Trihalomethanes [TTHMs] (ppb)*	80	N/A	24.8 - 64.6	57.5	N/A	N/A	Byproduct of drinking water disinfection
Uranium (pCi/L)	20	0.43	N/A	ND	1 - 2	2	Erosion of natural deposits

LEAD AND COPPER

Tap water samples were collected for lead and copper analyses from sample sites throughout the community

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	PHG	90TH% LEVEL	SITES ABOVE AL/ TOTAL SITES	TYPICAL SOURCE
Copper (ppm)	2011	1.3	0.3	0.085	0/30	Internal corrosion of household plumbing system; erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	2011	15	0.2	ND	1/30	Internal corrosion of household plumbing system; discharge from industrial manufactures; erosion of natural deposits

SECONDARY WATER STANDARDS

SUBSTANCE (UNIT OF MEASURE)	MCL [MRDL]	PHG [MCLG]	GROUNDWATER & DISTRIBUTION		MWD		TYPICAL SOURCE
			RANGE	DETECTED AVERAGE LEVEL (2013)	RANGE	DETECTED AVERAGE LEVEL (2013)	
Aluminum (ppm)	200	600	N/A	ND	95 - 220	140	Erosion of natural deposits; residue from some surface water treatment processes
Chlorine (ppm)	500	N/A	N/A	164	84 - 91	88	Runoff/leaching from natural deposits; seawater influence
Color** (units)	15	N/A	0	0	1	1	Naturally-occurring organic materials
Iron** (ppb)	300	N/A	ND	ND	ND	ND	Leaching from natural deposits; industrial wastes
Manganese** (ppb)	50	N/A	ND	ND	ND	ND	Leaching from natural deposits
Odor Threshold** (TON)	3	N/A	0	0	3 - 6	4	Naturally-occurring organic materials
Specific Conductance (µS/cm)	1600	N/A	N/A	1320	850 - 890	870	Runoff/leaching from natural deposits; seawater influence
Sulfate (ppm)	500	N/A	N/A	105	170 - 190	180	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (ppm)	1000	N/A	N/A	770	520 - 540	530	Runoff/leaching from natural deposits
Turbidity** (NTU)	5	N/A	0 - 0.11	ND	ND	ND	Soil runoff

OTHER PARAMETERS

SUBSTANCE (UNIT OF MEASURE)	GROUNDWATER & DISTRIBUTION		MWD	
	RANGE	DETECTED AVERAGE LEVEL (2013)	RANGE	DETECTED AVERAGE LEVEL (2013)
Alkalinity (ppm)	N/A	303	76 - 130	110
Calcium (ppm)	N/A	90.2	56 - 61	58
Hardness (ppm)	N/A	348	230 - 250	240
Magnesium (ppm)	N/A	29.9	21 - 23	22
pH** (units)	6.52 - 7.93	7.27	N/A	N/A
Potassium (ppm)	N/A	7.43	4.0 - 4.3	4.2
Sodium (ppm)	N/A	140	79 - 85	82

UNREGULATED CONTAMINANT MONITORING RULE 3 (UCMR 3)

UCMR - As part of the 1996 Amendments to the Federal Safe Drinking Water Act, the USEPA requires utilities to sample for emerging contaminants as part of the Unregulated Contaminant Monitoring Rule (UCMR). Every five (5) years the USEPA prepares a list of unregulated contaminants for utilities to analyze. UCMR results are then used to assist the development of future drinking water regulations. Last year, water utilities completed round three (3) of the UCMR. For more information please contact your local water retailer or visit the USEPA website <http://water.epa.gov/lawsregs/rulesregs/sdwa/ucmr/ucmr3/>

