

CITY OF LOMITA



# Cypress Water Production Facility Monthly Status Report

---

April 2017

## TABLE OF CONTENTS

COVER LETTER .....	1
A. BACKGROUND .....	2
B. WELL PRODUCTION AND OPERATIONS .....	2
C. OPERATIONAL INTERRUPTIONS .....	2
D. SAMPLE LOCATIONS .....	2
E. WATER QUALITY MONITORING .....	3
E1. IRON, MANGANESE AND COLOR .....	3
E2. FREE AND TOTAL CHLORINE RESIDUALS .....	3
E3. TOTAL DISSOLVED SOLIDS (TDS), ODOR, HARDNESS AND METHANE...	3
E3-1 TOTAL DISSOLVED SOLIDS (TDS) .....	3
E3-2 HARDNESS .....	3
E3-3 DISSOLVED METHANE (IN WATER) .....	4
E3-4 METHANE (IN AIR) .....	4
E3-5 ODOR .....	4
E4. NITRIFICATION MONITORING .....	4
F. TABLES .....	5

**CITY COUNCIL**

MARK WARONEK  
MICHAEL G. SAVIDAN  
JIM GAZELEY  
HENRY SANCHEZ, JR  
BEN TRAINA



**CITY OF LOMITA**

**ADMINISTRATION**

RYAN SMOOT  
CITY MANAGER

May 10, 2017

Mr. Paul Williams, P.E.  
District Engineer – Hollywood District  
State Water Resources Control Board – Division of Drinking Water  
500 North Central Avenue, Suite 500  
Glendale, CA 91203

Subject: System No. 1910073 - Monthly Report for the Cypress Water Production Facility (CWPF) for the period of April 1 through April 30, 2017.

Dear Mr. Williams,

In accordance with the Department of Public Health temporary approval letter dated March 15, 2013 and Permit Amendment No. 1910073, I am submitting the following report for the Cypress Water Production Facility operations for the month of April 2017.

If you should have any questions or concerns, please contact me at 310-325-7110 Ext. 124.

Sincerely,

Mark A. McAvoy, P.E.  
Public Works Director/City Engineer

## A. BACKGROUND

On March 15, 2013, the City of Lomita received conditional approval from the Department of Public Health (DPH) to distribute blended water from the Cypress Water Production Facility (CWPF) Well No. 5 to the City's customers.

The CWPF is an iron-manganese greensand filtration treatment system designed to remove primarily iron, manganese, and color. The CWPF was recently modified to enable aeration and blending with Metropolitan Water District (MWD) imported water to address the aesthetic secondary issues of Total Dissolved Solids (TDS), Hardness (as Calcium Carbonate), and Taste/Odor.

The CWPF came online on April 1, 2013. The first week of operations from April 1 to April 5, 2013 was utilized for conducting routine startup activities. The distribution of blended water to the City's residents began on April 5, 2013.

## B. WELL PRODUCTION

The CWPF operated continuously during the month of April 2017 maintaining water levels inside the reservoir ranging from 7 feet to 10 feet. The average flow from Well No. 5 was 500 gpm and 503 gpm from MWD. The blend ratio for month was 50% Well water and 50% MWD water. See Table 1 below for production totals for the month of April 2017.

Table 1. Monthly Production Totals.

	Production for April 2017		
Well No. 5	57.16	ac-ft	(18,624,452 gallons)
MWD	57.82	ac-ft	(18,839,000 gallons)
Combined Total	114.98	ac-ft	(37,463,440 gallons)
Daily	3.83	ac-ft/day	(1,248,781 gallons/day)

## C. OPERATIONAL INTERRUPTIONS

There were no operational interruptions during the month of April 2017. Routine and preventive maintenance was performed on various pieces of equipment as-needed. No major planned operational interruptions are anticipated for the following month.

## D. SAMPLE LOCATIONS

Compliance monitoring is performed at the following sample locations: SP1, SP2, SP3, SP5, and SP6. The SP1 sample location is the raw well water sample location. The SP2 sample location is on the effluent side of the greensand filter (before ammonia injection or full chloramination). The SP3 sample location is downstream of the greensand filter after full chloramination and the static mixer before entering the reservoir. The SP5 sample location is the reservoir effluent sample location before entering the distribution system. The SP6 sample location is the MWD source sample location before blending occurs.



## **E. WATER QUALITY MONITORING**

All water quality monitoring analyses were performed by laboratories certified by the Department of Health's Environmental Laboratory Accreditation Branch (ELAB). The CWPF has been continuously monitored, maintained and inspected, per the CWPF Operations Monitoring and Maintenance Plan. A brief discussion of the laboratory and/or monitoring results is provided below. Monthly monitoring at sample locations SP1, SP2 and SP6 were missed during April 2017 due to staff miscommunication. Sample location SP indicates water quality was met entering the distribution system. Refer to Appendix A for laboratory results.

### **E1. IRON, MANGANESE AND COLOR**

See Table 2 below for a summary of the results for the compliance monitoring at the three sample locations SP1 through SP3. Iron and Manganese levels before entering the reservoir (SP3) show non-detect, indicating the greensand filtration system remains highly effective.

### **E2. FREE AND TOTAL CHLORINE RESIDUALS**

Daily free chlorine residuals were monitored at SP2, SP3, SP4 and SP5. Daily total chlorine residuals were monitored at SP3, SP4 and SP5. Free chlorine and total chlorine residuals, at all respective sample points, were monitored using a combination of continuous chlorine analyzers and SCADA. See Table 3 below for a weekly summary of results.

### **E3. TOTAL DISSOLVED SOLIDS (TDS), ODOR, HARDNESS AND METHANE**

See Table 4 below for a summary of the results for the monitoring of Total Dissolved Solids (TDS), Odor (as measured by the Threshold Odor No. - T.O.N.), Total Hardness as Calcium Carbonate, and Methane levels in water at three sample locations SP1, SP5 and SP6.

#### **E3-1 TOTAL DISSOLVED SOLIDS (TDS)**

The sampling results indicate the TDS levels of the effluent blended water to be on average 535 mg/L. The TDS level of the effluent water meets the City's Water Quality Objective/Goal of 500 to 750 mg/L. The sampling results indicate the TDS levels in the raw water to be 790 mg/L.

#### **E3-2 HARDNESS**

The sampling results for the month indicate the hardness levels of the blended water to be on average 320 mg/L. This hardness level is in the upper range of the City's Water Quality Objective/Goal of 180 to 250 mg/L; staff continues to monitor hardness levels at the CWPF effluent (SP5) and within the water distribution system. The City has maintained a consistent blend ratio to ensure acceptable hardness levels are met.

Staff continues to use an orthophosphate/polyphosphate additive to sequester calcium hardness. Orthophosphate/Polyphosphate is a food grade National Sanitation Foundation (NSF 60) approved additive which decreases iron tuberculation, diminishes calcium scale deposits, minimizes corrosion, reduces discoloration, reduces staining and mineral build-up resulting in fewer customer complaints.

### **E3-3 DISSOLVED METHANE (IN WATER)**

The methane levels in the CWPF effluent after aeration treatment remain negligible averaging 0.45 mg/L.

### **E3-4 METHANE (IN AIR)**

The methane levels in the reservoir headspace are monitored daily by staff using a handheld device. These readings have consistently read non-detect to low concentrations for methane in air. Available methane hand held monitoring instruments can only detect levels of 1% Lower Explosive Limit (LEL) or greater. The handheld methane readings during the month were below the 50,000 ppm LEL. See attached methane log for the month of April 2017 in Appendix B.

### **E3-5 ODOR**

The odor levels at the CWPF effluent averaged 2 units for the month.

## **E4. NITRIFICATION MONITORING**

Weekly Nitrification sampling was performed during the month of April 2017, see Appendix C.

## F. TABLES

Table 2. Monitoring Results for SP1, SP2, and SP3 Sample Locations.

Date, week of	SP1, Well Raw Water Discharge							SP2, Combined Pressure Filter Effluent			SP3, After chloramination static mixer; reservoir entry					
	Iron, ug/L	*MCL = 3 00 ug/L	Manganese, ug/L	*MCL = 50 ug/L	Color	*MCL=15	Total Coliform	Total Coliform	HPC, MPN/100mL	MCL=500	Iron, mg/L	*MCL = 300 ug/L	Manganese, mg/L	*MCL = 50 ug/L	Color	*MCL=15
4/5/2017											ND	300	ND	50	5	15
4/12/2017	x	300	x	50	x	15	x	x	x	500	ND	300	ND	50	5	15
4/19/2017											ND	300	ND	50	5	15
4/26/2017											ND	300	ND	50	ND	15

**Notes:**

Monthly- Orange; Weekly- Yellow

A – Absent

ND – Non Detect

\*Per the SWRCB Drinking Water “Chemicals and Contaminants in Drinking Water” Regulations

“X”-Not taken during the month of April 2017

Table 3. Monitoring Results for Free and Total Chlorine at SP2, SP3, SP4 and SP5 Sample Locations.

Date, week of	SP2	SP3			SP4			SP5		
	Free Cl	Free Cl	Total Cl	Total NH <sub>3</sub>	Free Cl	Total Cl	Total NH <sub>3</sub>	Free Cl	Total Cl	Total NH <sub>3</sub>
4/5/2017	5.06	0.51	5.60	0.85	0.43	3.97	0.70	0.07	3.31	0.64
4/12/2017	5.41	0.55	5.38	0.97	0.42	4.12	0.74	0.07	3.38	0.69
4/19/2017	4.07	0.36	5.26	1.09	0.38	4.09	0.75	0.07	3.43	0.73
4/26/2017	4.38	0.25	5.63	1.02	0.30	4.19	0.74	0.06	3.30	0.68

Table 4. Monitoring Requirements and Frequencies for SP1, SP5, and SP6.

Date, week of	TDS, mg/L				T.O.N.		Hardness, mg/L				Methane (Water), mg/L	
	SP1 - Raw Well Water	SP6 - MWD Water	SP5 - Reservoir Effluent	Goal= 500 - 750 mg/L	SP5 - Reservoir Effluent	MCL= 3	SP1 - Raw Well Water	SP6 - MWD Water	SP5 - Reservoir Effluent	Goal= 180 - 250 mg/L	SP1 - Raw Well Water	SP5 - Reservoir Effluent
4/5/2017	**790	x	510	500-750	1	3	**350	**110	**320	180-250	x	0.49
4/12/2017			550	500-750	1	3				180-250		0.49
4/19/2017			530	500-750	4	3						0.39
4/26/2017			550	500-750	2	3						0.42
Average			535	500-750	2	3						0.45

**Notes:**

Monthly- Orange; Weekly- Yellow

ppm – parts per million

mg/L – milligram per liter

T.O.N. - Threshold Odor Number

TDS - Total Dissolved Solids

Hardness - As total CaCO<sub>3</sub>

Methane (Water) - Methane dissolved in water

"X" - Not taken during the month of April 2017

\*\* Samples collected and analyzed in-house



**Cypress Water Production Facility**  
**City of Lomita; System No. 1910073**

Sample Locations and Parameters	Frequency	MCL/ Goal	4/5	4/12	4/19	4/26	N/A	Comments and/or Other Info.
			1stWk	2 <sup>nd</sup> Wk	3rdWk	4 <sup>th</sup> Wk	5 <sup>th</sup> Wk	
or <b>Mo. Result (date)</b>								
<b>SP1 --- Also called Well 5 Raw Water or Site#1.</b>								
TDS, ppm	Monthly	See SP5	790 4/5/17	<b>Operations Data/Information:</b>  <b>CWPF operation days:</b> 30  <b>On Well 5:</b> Daily average flow - 500 gpm; total prod. - 57.16 AF <b>Combined Well 5/MWD data:</b> Average Well 5: MWD blend Ratio - 50% WELL:50% MWD; total prod.- 114.98 AF  Chlorine Dosage: N/A*				*Chlorine injected after SP1, before entering the greensand filter.  "x" - Not taken during the month of April 2017  <b>Blue</b> - sample collected and analyzed in-house
Hardness	Monthly	See SP5	350 4/5/17					
CH4, ppm	Monthly	See SP5	x					
Iron, ppb	Monthly	See SP3	x					
Manganese, ppb	Monthly	See SP3	x					
Color, units	Monthly	See SP3	x					
Total Coliform, P or A	Monthly	A	x					
<b>SP2 --- Also called Filter Effluent or Site#3.</b>								
Total Coliform, P or A	Monthly	A	x	Ammonia Dosage: N/A*				*Ammonia added after filter effluent "x" - Not taken during the month of April 2017
HPC,MPN/100 ml	Monthly	500	x					
Free Cl Res, ppm	Continuous	Average: 4.67; Range: 4.07 - 5.41						
<b>SP3 --- Also called the Site After Chloramination &amp; Before MWD Blending or Site#4.</b>								
Iron, ppb	Weekly	300	ND	ND	ND	ND		
Manganese, ppb	Weekly	50	ND	ND	ND	ND		
Color	Weekly	15	5	5	5	ND		
Free and Total Cl Res, ppm	Continuous	Free Cl: Average: 0.39; Range: 0.25 - 0.55 Total Cl: Average: 5.46; Range: 5.26 - 5.63 Ammonia: Average: 1.00; Range: 0.85 - 1.09						
<b>SP4 --- Also called Reservoir Influent or the Site Well 5/MWD Water Blend Point/Phosphate Injection.</b>								
Phosphate Injection		Phosphate Dosage: 0.75 mg/L						
Free and Total Cl Res, ppm	Continuous	Free Cl: Average: 0.37; Range: 0.30 - 0.43 Total Cl: Average: 4.06; Range: 3.95 - 4.19 Ammonia: Average: 0.73; Range: 0.70 - 0.75						Cl/NH3 Ratio: 5.56
<b>SP5 --- Also called Reservoir Effluent or Site#5. SP5 discharges into Zone 1 of the distribution system.</b>								
TDS, ppm	Weekly	SI Goal: 500-750ppm	510	550	530	550		Blue - sample collected and analyzed in-house
Hardness	Monthly	SI Goal: 180-250ppm	320					
CH4, ppm	Weekly	Goal: from PA	0.49	0.49	0.39	0.42		% CH4 Removal: -
Odor, units	Monthly	1	1	1	4	2		
Free and Total Cl Res, ppm	Continuous	Free Cl: Average: 0.07; Range: 0.06 - 0.07 Total Cl: Average: 3.36; Range: 3.30 - 3.43 Ammonia: Average: 0.68; Range: 0.64 - 0.73						Cl/NH3 Ratio: 4.92
<b>Headspace of the Cypress Reservoir.</b>								
1CH4 ppmv; using Portable Device	Daily (from log)	Goal - LEL	CH4 Average: 0.06% CH4 Range: 0% - 1%					
<b>SP 6 --- MWD Source Feeding CWPF. Also called Zone 2 of the distribution system or Site #6.</b>								
TDS, ppm	Monthly	-----		x				"x" - Not taken during the month of April 2017 Blue - sample collected and analyzed in-house
Hardness	Monthly	-----		110				
Notes: 1Self-Imposed (SI) Goals: TDS Goal-500-750 ppm; Hardness as CaCO3 Goal-180-250 ppm.								
***This Report is due to DDW by the 10 <sup>th</sup> of the following month.								

Other Notes/Comments: (1) See comments on the last column



## **APPENDIX A**

### LABORATORY RESULTS

# *Clinical Laboratory of San Bernardino, Inc.*



21 April 2017

Clinical Lab No.: 17D0523

Mark Andersen  
Lomita, City of  
24373 Walnut Avenue  
Lomita, CA 91717

Project Name: Standard Analysis  
Sub Project: CWPF 1st Week April 2017 Compliance Sampling

Enclosed are the results of the analyses for samples received at the laboratory on 04/05/17. Samples were received within temperature range, in correct containers and preservation.

Analyses were performed pursuant to client's chain of custody, within hold times, utilizing EPA or other ELAP approved methodologies.

I certify that the results are within compliance both technically and for completeness. Analytical results are attached to this letter. Please call if any additional information and or assistance are needed.

Thank you for choosing Clinical Laboratory of San Bernardino for your analytical needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Stu Styles', with a stylized flourish at the end.

Stu Styles  
Client Services Manager

# Clinical Laboratory of San Bernardino, Inc.



**Lomita, City of**  
24373 Walnut Avenue  
Lomita CA, 91717

Project: Standard Analysis  
Sub Project: CWPf 1st Week April 2017 Compliance Sampling  
Project Manager: Mark Andersen

Work Order: 17D0523  
Received: 04/05/17 15:15  
Reported: 04/21/17

**Reservoir Influent Site #3** **17D0523-01 (Water)** **Sample Date:** 04/05/17 9:20 **Sampler:** PLM

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

## Field Analyses

<b>Cl Res Total (Field)</b>	Field	<b>5.35</b>		N/A	mg/L	04/05/17	04/05/17	1715002	
<b>pH (Field)</b>	Field	<b>7.6</b>		N/A	pH Units	04/05/17	04/05/17	1715002	
<b>Temperature (Field)</b>	Field	<b>22</b>		N/A	°C	04/05/17	04/05/17	1715002	

## General Physical Analyses

<b>Apparent Color</b>	SM 2120B-M	<b>5.0</b>	3.0	15	Color Units	04/05/17	04/05/17	1714147	
-----------------------	---------------	------------	-----	----	-------------	----------	----------	---------	--

## Metals

Iron (Fe)	EPA 200.7	ND	100	300	ug/L	04/17/17	04/17/17	1716007	
Manganese (Mn)	EPA 200.7	ND	20	50	ug/L	04/17/17	04/17/17	1716007	

**Reservoir Effluent Site #5** **17D0523-02 (Water)** **Sample Date:** 04/05/17 9:25 **Sampler:** PLM

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

## Field Analyses

<b>Cl Res Total (Field)</b>	Field	<b>3.06</b>		N/A	mg/L	04/05/17	04/05/17	1715002	
<b>pH (Field)</b>	Field	<b>7.8</b>		N/A	pH Units	04/05/17	04/05/17	1715002	
<b>Temperature (Field)</b>	Field	<b>19.8</b>		N/A	°C	04/05/17	04/05/17	1715002	

## General Physical Analyses

<b>Apparent Color</b>	SM 2120B-M	ND	3.0	15	Color Units	04/05/17	04/05/17	1714147	
<b>Odor Threshold</b>	EPA 140.1-M	<b>1</b>	1	3	TON	04/05/17	04/05/17	1714147	

## General Chemical Analyses

<b>Total Filterable Residue/TDS</b>	SM 2540C	<b>510</b>	5.0	1000	mg/L	04/12/17	04/17/17	1715090	
-------------------------------------	----------	------------	-----	------	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit



April 14, 2017

Clinical Laboratory of San Bernardino  
ATTN: Stu Styles  
21881 Barton Rd.  
Grand Terrace, CA 92313



ADE-1461  
EPA Methods TO3,  
TO14A, TO15 SIM & SCAN  
ASTM D1946



LA Cert #04140  
EPA Methods TO3, TO14A, TO15, 25C/3C,  
RSK-175

TX Cert T104704450-14-6  
EPA Methods TO14A, TO15

UT Cert CA0133332015-3  
EPA Methods TO3, TO14A, TO15, RSK-175

### LABORATORY TEST RESULTS

Project Reference: 17D0523  
Lab Number: I040701-01

Enclosed are results for sample(s) received 4/07/17 by Air Technology Laboratories. Samples were received intact and properly chilled. Analyses were performed according to specifications on the chain of custody provided with the sample(s).

#### Report Narrative:

- Unless otherwise noted in the report, sample analyses were performed within method performance criteria and meet all requirements of the NELAC Standards.
- The enclosed results relate only to the sample(s).

ATL appreciates the opportunity to provide testing services to your company. If you have any questions regarding these results, please call me at (626) 964-4032.

Sincerely,

A handwritten signature in blue ink, appearing to read "Mark Johnson".

Mark Johnson  
Operations Manager  
MJohnson@AirTechLabs.com

Note: The cover letter is an integral part of this analytical report.

**SUBCONTRACT ORDER**  
**Clinical Laboratory of San Bernardino**  
**17D0523**

1040701-01

**SENDING LABORATORY:**

Clinical Laboratory of San Bernardino  
21881 Barton Road  
Grand Terrace, CA 92313  
Phone: 909.825.7693  
Fax: 909.825.7696  
Project Manager: Stu Styles

**RECEIVING LABORATORY:**

Air Technology Labs  
18501 East Gale Avenue Suite 130  
City of Industry, CA 91748  
Phone : (626) 964-4032  
Fax:

Please email results to Project Manager: Stu Styles

[ ] glaubig@clinical-lab.com [ ] ybarra@clinical-lab.com [x] styles@clinical-lab.com [ ] nelson@clinical-lab.com

California EDT transfer those samples with PS codes provided [ ] Yes [x] No

Water Trax Upload Client: [ ] Yes [x] No

Turn Around Time [ ] 10 Days [x] 5 Days [ ] Other \_\_\_ Days

Subcontract Comments:

**Analysis**

**Comments**

**Sample ID: Reservoir Effluent Site #5 / 17D0523-02**

**Sampled: 04/05/17 09:25 PS Code:**  
**Water**

**WTX ID:**

Methane RSK175

Report in mg/L

Containers Supplied:

40ml Amber Vial (B)

40ml Amber Vial (C)

Released By

Date / Time

Received By

Date / Time

Released By

Date / Time

Received By

Date / Time

20°C

Released By: *Stu Styles* Date / Time: *04/07/17 07:30* Received By: *Henry Pizarro* Date / Time: *4/7/17 830*  
Released By: *Henry Pizarro* Date / Time: *4/7/17 932* Received By: *[Signature]* Date / Time: *4/7/17 0932*



**Client:** Clinical Laboratory  
**Attn:** Stu Styles  
**Project Name:** NA  
**Project No.:** 17D0523  
**Date Received:** 04/07/17  
**Matrix:** Water  
**Reporting Units:** mg/L

RSK175

<b>Lab No.:</b>	<b>I040701-01</b>								
<b>Client Sample I.D.:</b>	<b>Reservoir Effluent Site #5/17D0523- 02</b>								
<b>Date/Time Sampled:</b>	<b>4/5/17 9:25</b>								
<b>Date/Time Analyzed:</b>	<b>4/10/17 9:31</b>								
<b>QC Batch No.:</b>	<b>170410GC8A1</b>								
<b>Analyst Initials:</b>	<b>AS</b>								
<b>Dilution Factor:</b>	<b>1.0</b>								
<b>ANALYTE</b>	<b>Result mg/L</b>	<b>RL mg/L</b>							
<b>Methane</b>	<b>0.49</b>	<b>0.0010</b>							

ND = Not Detected (below RL)

RL = Reporting Limit

Reviewed/Approved By: Mark Johnson  
 Mark Johnson  
 Operations Manager

Date 4/14/17

The cover letter is an integral part of this analytical report



QC Batch No.: 170410GC8A1  
Matrix: Water  
Units: mg/L

QC for Dissolved Gases by EPA Procedure RSKSOP-175

Lab No.:		Method Blank		LCS		LCSD			
Date/Time Analyzed:		4/10/17 9:18		4/10/17 8:37		4/10/17 9:04			
Analyst Initials:		AS		AS		AS			
Datafile:		10apr004		10apr001		10apr003			
Dilution Factor:		1.0		1.0		1.0			
ANALYTE	PQL	RL	Results	% Rec.	Criteria	% Rec.	Criteria	%RPD	Criteria
Methane	0.001	0.001	ND	107	70-130%	98	70-130%	8.3	<30

PQL = Practical Quantitation Limit

ND = Not Detected (Below RL).

RL = PQL X Dilution Factor

Reviewed/Approved By: \_\_\_\_\_

Mark J. Johnson  
Operations Manager

Date: \_\_\_\_\_

The cover letter is an integral part of this analytical report.



**AirTECHNOLOGY Laboratories, Inc.**

18501 E. Gale Avenue, Suite 130 ♦ City of Industry, CA 91748 ♦ Ph: (626) 964-4032 ♦ Fx: (626) 964-5832

Client		City of Lomita		System Number		Analysis Requested															
Address		24373 Walnut Avenue Lomita, CA 91717 (310) 325-9830 (310) 325-3627 Standard Analysis		1910073																	
Phone #		(310) 325-9830		Destination Laboratory																	
Fax #		(310) 325-3627		[X] Clinical Laboratory																	
Project		CW/PF IST week of APRIL, 2017 Compliance Sampling		RWQCB Compliance																	
Sub Project		For TC/EC/BACT see weekly Distro CoC PLM		ELAP #																	
Comments		PLM		1088																	
Sampled by																					
Date	Time	Sample Identification	Matrix	Type	Preserv	Total Chlorine	Iron				Manganese	Total Dissolved Solids	Color	Methane (Water) (RSK175)	Total Hardness (as CaCO <sub>3</sub> )	BACT/TC/HPC	Odor		Comments / P.S. Codes		
4/5/2017	0720	Reservoir Influent Site #3	DW	1W	N/A	5.35	X	X	X	X	X	X	X	X					ph 7.6 temp 22.0°		
4/5/2017	0725	Reservoir Effluent Site #5	DW	1W	N/A	3.06											X	ph 7.80 temp 19.8°			
4/5/2017	0725	Reservoir Effluent Site #5	DW	1W	HCL	3.06									X						
Preservatives:		(1) Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> (2) HCl (3) HNO <sub>3</sub> (4) NH <sub>4</sub> Cl (5) H <sub>2</sub> SO <sub>4</sub> (6) Na <sub>2</sub> SO <sub>3</sub> (7) Cold (8) Other:				Matrix: DW-Drinking Water, WW-Waste Water, SW-Storm Water, GW-Ground Water, A-Air Routine, 2-Repeat, 3-Replacement, 4-Special W-Well D-Dist.															Type-1-
Relinquished By (Sign)		Print Name / Company		Date / Time		Received By (Sign)		Print Name / Company													
Patrick McCue		City of Lomita		4/5/17 / 1:30				J. Luceno / CSB													
Comments:		J. Luceno / CSB		4-5-15 / 3:15				On ice X Intact ( ) Custody seals Temp 10.1 ( ) F ( )													
Shipped Via		Fed X Golden State UPS Client Other								Page 1 of 1											

# *Clinical Laboratory of San Bernardino, Inc.*



28 April 2017

Clinical Lab No.: 17D0989

Mark Andersen  
Lomita, City of  
24373 Walnut Avenue  
Lomita, CA 91717

Project Name: Standard Analysis  
Sub Project: CWPF 2nd Week April 2017 Compliance Sampling

Enclosed are the results of the analyses for samples received at the laboratory on 04/12/17. Samples were received within temperature range, in correct containers and preservation.

Analyses were performed pursuant to client's chain of custody, within hold times, utilizing EPA or other ELAP approved methodologies.

I certify that the results are within compliance both technically and for completeness. Analytical results are attached to this letter. Please call if any additional information and or assistance are needed.

Thank you for choosing Clinical Laboratory of San Bernardino for your analytical needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Stu Styles', with a stylized flourish at the end.

Stu Styles  
Client Services Manager

# Clinical Laboratory of San Bernardino, Inc.



**Lomita, City of**  
24373 Walnut Avenue  
Lomita CA, 91717

Project: Standard Analysis  
Sub Project: CWPf 2nd Week April 2017 Compliance Sampling  
Project Manager: Mark Andersen

Work Order: 17D0989  
Received: 04/12/17 14:45  
Reported: 04/28/17

**Reservoir Influent Site #3** **17D0989-01 (Water)** **Sample Date:** 04/12/17 7:15 **Sampler:** DM

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

## Field Analyses

Cl Res Total (Field)	Field	5.4		N/A	mg/L	04/12/17	04/12/17	1715112	
pH (Field)	Field	7.61		N/A	pH Units	04/12/17	04/12/17	1715112	
Temperature (Field)	Field	21.6		N/A	°C	04/12/17	04/12/17	1715112	

## General Physical Analyses

Apparent Color	SM 2120B-M	5.0	3.0	15	Color Units	04/12/17	04/12/17	1715170	
----------------	---------------	-----	-----	----	-------------	----------	----------	---------	--

## Metals

Iron (Fe)	EPA 200.7	ND	100	300	ug/L	04/20/17	04/20/17	1716066	
Manganese (Mn)	EPA 200.7	ND	20	50	ug/L	04/20/17	04/20/17	1716066	

**Reservoir Effluent Site #5** **17D0989-02 (Water)** **Sample Date:** 04/12/17 7:30 **Sampler:** DM

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

## Field Analyses

Cl Res Total (Field)	Field	3.4		N/A	mg/L	04/12/17	04/12/17	1715112	
pH (Field)	Field	7.83		N/A	pH Units	04/12/17	04/12/17	1715112	
Temperature (Field)	Field	19.3		N/A	°C	04/12/17	04/12/17	1715112	

## General Physical Analyses

Apparent Color	SM 2120B-M	ND	3.0	15	Color Units	04/12/17	04/12/17	1715170	
Odor Threshold	EPA 140.1-M	1	1	3	TON	04/12/17	04/12/17	1715170	

## General Chemical Analyses

Total Filterable Residue/TDS	SM 2540C	550	5.0	1000	mg/L	04/19/17	04/24/17	1716085	
------------------------------	----------	-----	-----	------	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit





April 20, 2017

Clinical Laboratory of San Bernardino  
ATTN: Stu Styles  
21881 Barton Rd.  
Grand Terrace, CA 92313



ADE-1461  
EPA Methods TO3,  
TO14A, TO15 SIM & SCAN  
ASTM D1946



LA Cert #04140  
EPA Methods TO3, TO14A, TO15, 25C/3C,  
RSK-175

TX Cert T104704450-14-6  
EPA Methods TO14A, TO15

UT Cert CA0133332015-3  
EPA Methods TO3, TO14A, TO15, RSK-175

### LABORATORY TEST RESULTS

Project Reference: 17D0989  
Lab Number: I041307-01

Enclosed are results for sample(s) received 4/13/17 by Air Technology Laboratories. Samples were received intact and properly chilled. Analyses were performed according to specifications on the chain of custody provided with the sample(s).

#### Report Narrative:

- Unless otherwise noted in the report, sample analyses were performed within method performance criteria and meet all requirements of the NELAC Standards.
- The enclosed results relate only to the sample(s).

ATL appreciates the opportunity to provide testing services to your company. If you have any questions regarding these results, please call me at (626) 964-4032.

Sincerely,

A handwritten signature in blue ink, appearing to read "Mark Johnson".

Mark Johnson  
Operations Manager  
MJohnson@AirTechLabs.com

Note: The cover letter is an integral part of this analytical report.

SUBCONTRACT ORDER  
Clinical Laboratory of San Bernardino  
17D0989

I041307-01

SENDING LABORATORY:Clinical Laboratory of San Bernardino  
21881 Barton Road  
Grand Terrace, CA 92313  
Phone: 909.825.7693  
Fax: 909.825.7696  
Project Manager: Stu StylesRECEIVING LABORATORY:Air Technology Labs  
18501 East Gale Avenue Suite 130  
City of Industry, CA 91748  
Phone : (626) 964-4032  
Fax:

Please email results to Project Manager: Stu Styles

[ ] glaubig@clinical-lab.com [ ] ybarra@clinical-lab.com [x] styles@clinical-lab.com [ ] nelson@clinical-lab.com

California EDT transfer those samples with PS codes provided [ ] Yes [x] No

Water Trax Upload Client: [ ] Yes [x] No

Turn Around Time [ ] 10 Days [x] 5 Days [ ] Other \_\_\_ Days

Subcontract Comments:

AnalysisComments

Sample ID: Reservoir Effluent Site #5 / 17D0989-02

Sampled: 04/12/17 07:30 PS Code:  
Water

WTX ID:

Methane RSK175

Report in mg/L

Containers Supplied:

40ml Amber Vial (B)

40ml Amber Vial (C)

10°C

Released By

Date / Time

Received By

Date / Time

Released By

Date / Time

Received By

Date / Time

**Client:** Clinical Laboratory  
**Attn:** Stu Styles  
**Project Name:** NA  
**Project No.:** 17D0989  
**Date Received:** 04/13/17  
**Matrix:** Water  
**Reporting Units:** mg/L

RSK175

Lab No.:	I041307-01						
Client Sample I.D.:	Reservoir Effluent Site #5/17D0989- 02						
Date/Time Sampled:	4/12/17 7:30						
Date/Time Analyzed:	4/19/17 9:49						
QC Batch No.:	170419GC8A1						
Analyst Initials:	AS						
Dilution Factor:	1.0						
ANALYTE	Result mg/L	RL mg/L					
Methane	0.49	0.0010					

ND = Not Detected (below RL)  
 RL = Reporting Limit

Reviewed/Approved By: \_\_\_\_\_



Mark Johnson  
Operations Manager

Date

4-20-17

The cover letter is an integral part of this analytical report



QC Batch No.: 170419GC8A1  
Matrix: Water  
Units: mg/L

## QC for Dissolved Gases by EPA Procedure RSKSOP-175

Lab No.:		Method Blank		LCS		LCSD			
Date/Time Analyzed:		4/19/17 9:07		4/19/17 9:23		4/19/17 14:58			
Analyst Initials:		AS		AS		AS			
Datafile:		19apr002		19apr003		19apr025			
Dilution Factor:		1.0		1.0		1.0			
ANALYTE	PQL	RL	Results	% Rec.	Criteria	% Rec.	Criteria	%RPD	Criteria
Methane	0.001	0.001	ND	103	70-130%	101	70-130%	1.9	<30

PQL = Practical Quantitation Limit

ND = Not Detected (Below RL).

RL = PQL X Dilution Factor

Reviewed/Approved By: \_\_\_\_\_

  
Mark J. Johnson  
Operations Manager

Date: 4-20-17

The cover letter is an integral part of this analytical report.



**AirTECHNOLOGY Laboratories, Inc.**

18501 E. Gale Avenue, Suite 130 ♦ City of Industry, CA 91748 ♦ Ph: (626) 964-4032 ♦ Fx: (626) 964-5832

*"Your Water and Wastewater Analysis Solution"*



# *Clinical Laboratory of San Bernardino, Inc.*



04 May 2017

Clinical Lab No.: 17D1551

Mark Andersen  
Lomita, City of  
24373 Walnut Avenue  
Lomita, CA 91717

Project Name: Standard Analysis  
Sub Project: CWPF 3rd week April Compliance Sampling

Enclosed are the results of the analyses for samples received at the laboratory on 04/19/17. Samples were received within temperature range, in correct containers and preservation.

Analyses were performed pursuant to client's chain of custody, within hold times, utilizing EPA or other ELAP approved methodologies.

I certify that the results are within compliance both technically and for completeness. Analytical results are attached to this letter. Please call if any additional information and or assistance are needed.

Thank you for choosing Clinical Laboratory of San Bernardino for your analytical needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Stu Styles', with a stylized flourish at the end.

Stu Styles  
Client Services Manager

# Clinical Laboratory of San Bernardino, Inc.



**Lomita, City of**  
24373 Walnut Avenue  
Lomita CA, 91717

Project: Standard Analysis  
Sub Project: CWPf 3rd week April Compliance Sampling  
Project Manager: Mark Andersen

Work Order: 17D1551  
Received: 04/19/17 15:10  
Reported: 05/04/17

**Reservoir Influent Site #3** **17D1551-01 (Water)** **Sample Date:** 04/19/17 9:00 **Sampler:** DGM

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

## Field Analyses

<b>Cl Res Total (Field)</b>	Field	<b>5.19</b>		N/A	mg/L	04/19/17	04/19/17	1716123	
<b>pH (Field)</b>	Field	<b>7.78</b>		N/A	pH Units	04/19/17	04/19/17	1716123	
<b>Temperature (Field)</b>	Field	<b>21.9</b>		N/A	°C	04/19/17	04/19/17	1716123	

## General Physical Analyses

<b>Apparent Color</b>	SM 2120B-M	<b>5.0</b>	3.0	15	Color Units	04/19/17	04/19/17	1716140	
-----------------------	---------------	------------	-----	----	-------------	----------	----------	---------	--

## Metals

Iron (Fe)	EPA 200.7	ND	100	300	ug/L	04/25/17	04/27/17	1717061	
Manganese (Mn)	EPA 200.7	ND	20	50	ug/L	04/25/17	04/27/17	1717061	

**Reservoir Effluent Site #5** **17D1551-02 (Water)** **Sample Date:** 04/19/17 9:15 **Sampler:** DGM

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

## Field Analyses

<b>Cl Res Total (Field)</b>	Field	<b>3.2</b>		N/A	mg/L	04/19/17	04/19/17	1716123	
<b>pH (Field)</b>	Field	<b>7.85</b>		N/A	pH Units	04/19/17	04/19/17	1716123	
<b>Temperature (Field)</b>	Field	<b>19.9</b>		N/A	°C	04/19/17	04/19/17	1716123	

## General Physical Analyses

<b>Apparent Color</b>	SM 2120B-M	ND	3.0	15	Color Units	04/19/17	04/19/17	1716140	
<b>Odor Threshold</b>	EPA 140.1-M	<b>4</b>	1	3	TON	04/19/17	04/19/17	1716140	

## General Chemical Analyses

<b>Total Filterable Residue/TDS</b>	SM 2540C	<b>530</b>	5.0	1000	mg/L	04/26/17	05/02/17	1717084	
-------------------------------------	----------	------------	-----	------	------	----------	----------	---------	--

ND Analyte NOT DETECTED at or above the reporting limit



April 27, 2017

Clinical Laboratory of San Bernardino  
ATTN: Stu Styles  
21881 Barton Rd.  
Grand Terrace, CA 92313



ADE-1461  
EPA Methods TO3,  
TO14A, TO15 SIM & SCAN  
ASTM D1946



LA Cert #04140  
EPA Methods TO3, TO14A, TO15, 25C/3C,  
RSK-175

TX Cert T104704450-14-6  
EPA Methods TO14A, TO15

UT Cert CA0133332015-3  
EPA Methods TO3, TO14A, TO15, RSK-175

### LABORATORY TEST RESULTS

Project Reference: 17D1551  
Lab Number: I042003-01

Enclosed are results for sample(s) received 4/20/17 by Air Technology Laboratories. Samples were received intact and properly chilled. Analyses were performed according to specifications on the chain of custody provided with the sample(s).

#### Report Narrative:

- Unless otherwise noted in the report, sample analyses were performed within method performance criteria and meet all requirements of the NELAC Standards.
- The enclosed results relate only to the sample(s).

ATL appreciates the opportunity to provide testing services to your company. If you have any questions regarding these results, please call me at (626) 964-4032.

Sincerely,

A handwritten signature in blue ink, appearing to read "m. johnson", is written over a light blue horizontal line.

Mark Johnson  
Operations Manager  
MJohnson@AirTechLabs.com

Note: The cover letter is an integral part of this analytical report.

**SUBCONTRACT ORDER**  
**Clinical Laboratory of San Bernardino**  
**17D1551**

I042003-01

**SENDING LABORATORY:**

Clinical Laboratory of San Bernardino  
21881 Barton Road  
Grand Terrace, CA 92313  
Phone: 909.825.7693  
Fax: 909.825.7696  
Project Manager: Stu Styles

**RECEIVING LABORATORY:**

Air Technology Labs  
18501 East Gale Avenue Suite 130  
City of Industry, CA 91748  
Phone : (626) 964-4032  
Fax:

Please email results to Project Manager: Stu Styles

[ ] glaubig@clinical-lab.com [ ] ybarra@clinical-lab.com [x] styles@clinical-lab.com [ ] nelson@clinical-lab.com

California EDT transfer those samples with PS codes provided [ ] Yes [x] No  
Water Trax Upload Client: [ ] Yes [x] No

Turn Around Time [ ] 10 Days [x] 5 Days [ ] Other \_\_\_ Days

Subcontract Comments:

**Analysis**

**Comments**

Sample ID: Reservoir Effluent Site #5 / 17D1551-02

Sampled: 04/19/17 09:15 PS Code:  
Water

WTX ID:

Methane RSK175

Report in mg/L

Containers Supplied:

40ml Amber Vial (B)

40ml Amber Vial (C)

7°C

Released By	Bd Shy	Date / Time	04/20/17 08:15	Received By	Michael Salazar	Date / Time	4-20-17 9:30
Released By	Michael Salazar	Date / Time	4-20-17 9:53	Received By	Danji-	Date / Time	4/20/17 0953

**Client:** Clinical Laboratory  
**Attn:** Stu Styles  
**Project Name:** NA  
**Project No.:** 17D1551  
**Date Received:** 04/20/17  
**Matrix:** Water  
**Reporting Units:** mg/L

RSK175

Lab No.:	I042003-01						
Client Sample I.D.:	Reservoir Effluent Site #5/17D1551-02						
Date/Time Sampled:	4/19/17 9:15						
Date/Time Analyzed:	4/25/17 13:14						
QC Batch No.:	170425GC8A1						
Analyst Initials:	AS						
Dilution Factor:	1.0						
ANALYTE	Result mg/L	RL mg/L					
Methane	0.39	0.0010					

ND = Not Detected (below RL)  
 RL = Reporting Limit

Reviewed/Approved By: Mark Johnson  
 Mark Johnson  
 Operations Manager

Date 4/27/17

The cover letter is an integral part of this analytical report



QC Batch No.: 170425GC8A1  
Matrix: Water  
Units: mg/L

## QC for Dissolved Gases by EPA Procedure RSKSOP-175

Lab No.:		Method Blank		LCS		LCSD				
Date/Time Analyzed:		4/25/17 10:58		4/25/17 11:29		4/25/17 11:44				
Analyst Initials:		AS		AS		AS				
Datafile:		25apr002		25apr004		25apr005				
Dilution Factor:		1.0		1.0		1.0				
ANALYTE		PQL	RL	Results	% Rec.	Criteria	% Rec.	Criteria	%RPD	Criteria
Methane		0.001	0.001	ND	105	70-130%	108	70-130%	3.3	<30

PQL = Practical Quantitation Limit

ND = Not Detected (Below RL).

RL = PQL X Dilution Factor

Reviewed/Approved By: \_\_\_\_\_

Mark J. Johnson  
Operations Manager

Date: \_\_\_\_\_

The cover letter is an integral part of this analytical report.



**AirTECHNOLOGY Laboratories, Inc.**

18501 E. Gale Avenue, Suite 130 ♦ City of Industry, CA 91748 ♦ Ph: (626) 964-4032 ♦ Fx: (626) 964-5832

17D1551

## "Your Water and Wastewater Analysis Solution"



# *Clinical Laboratory of San Bernardino, Inc.*



04 May 2017

Clinical Lab No.: 17D2085

Mark Andersen  
Lomita, City of  
24373 Walnut Avenue  
Lomita, CA 91717

Project Name: Standard Analysis  
Sub Project: CWPF 4th week April Compliance Sampling

Enclosed are the results of the analyses for samples received at the laboratory on 04/26/17 . Samples were received within temperature range, in correct containers and preservation.

Analyses were performed pursuant to client's chain of custody, within hold times, utilizing EPA or other ELAP approved methodologies.

I certify that the results are within compliance both technically and for completeness. Analytical results are attached to this letter. Please call if any additional information and or assistance are needed.

Thank you for choosing Clinical Laboratory of San Bernardino for your analytical needs.

Sincerely,

A handwritten signature in black ink, appearing to read 'Stu Styles', with a stylized flourish at the end.

Stu Styles  
Client Services Manager

Work Order: 17D2085  
Received: 04/26/17 15:30  
Reported: 05/04/17

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
---------	--------	--------	------------	-----	-------	----------	----------	-------	-----------



May 4, 2017

Clinical Laboratory of San Bernardino  
ATTN: Stu Styles  
21881 Barton Rd.  
Grand Terrace, CA 92313



ADE-1461  
EPA Methods TO3,  
TO14A, TO15 SIM & SCAN  
ASTM D1946



LA Cert #04140  
EPA Methods TO3, TO14A, TO15, 25C/3C,  
RSK-175

TX Cert T104704450-14-6  
EPA Methods TO14A, TO15

UT Cert CA0133332015-3  
EPA Methods TO3, TO14A, TO15, RSK-175

### LABORATORY TEST RESULTS

Project Reference: 17D2085  
Lab Number: I042705-01

Enclosed are results for sample(s) received 4/27/17 by Air Technology Laboratories. Samples were received intact and properly chilled. Analyses were performed according to specifications on the chain of custody provided with the sample(s).

#### Report Narrative:

- Unless otherwise noted in the report, sample analyses were performed within method performance criteria and meet all requirements of the NELAC Standards.
- The enclosed results relate only to the sample(s).

ATL appreciates the opportunity to provide testing services to your company. If you have any questions regarding these results, please call me at (626) 964-4032.

Sincerely,

A handwritten signature in blue ink, appearing to read "Mark Johnson".

Mark Johnson  
Operations Manager  
MJohnson@AirTechLabs.com

Note: The cover letter is an integral part of this analytical report.

**SUBCONTRACT ORDER**  
**Clinical Laboratory of San Bernardino**  
**17D2085**

I042705-01

**SENDING LABORATORY:**

Clinical Laboratory of San Bernardino  
21881 Barton Road  
Grand Terrace, CA 92313  
Phone: 909.825.7693  
Fax: 909.825.7696  
Project Manager: Stu Styles

**RECEIVING LABORATORY:**

Air Technology Labs  
18501 East Gale Avenue Suite 130  
City of Industry, CA 91748  
Phone : (626) 964-4032  
Fax:

Please email results to Project Manager: Stu Styles

[ ] glaubig@clinical-lab.com [ ] ybarra@clinical-lab.com [x] styles@clinical-lab.com [ ] nelson@clinical-lab.com

California EDT transfer those samples with PS codes provided [ ] Yes [x] No  
Water Trax Upload Client: [ ] Yes [x] No

Turn Around Time [ ] 10 Days [x] 5 Days [ ] Other \_\_\_ Days  
Subcontract Comments:

**Analysis**

**Comments**

Sample ID: Reservoir Effluent Site #5 / 17D2085-02

Sampled: 04/26/17 08:10 PS Code:  
Water

WTX ID:

Methane RSK175

Report in mg/L

Containers Supplied:

40ml Amber Vial (B)

40ml Amber Vial (C)

30

Released By

Date / Time

Received By

Date / Time

Released By

Date / Time

Received By

Date / Time

**Client:** Clinical Laboratory  
**Attn:** Stu Styles  
**Project Name:** NA  
**Project No.:** 17D2085  
**Date Received:** 04/27/17  
**Matrix:** Water  
**Reporting Units:** mg/L

RSK175

Lab No.:	I042705-01						
Client Sample I.D.:	Reservoir Effluent Site #5/17D2085-02						
Date/Time Sampled:	4/26/17 8:10						
Date/Time Analyzed:	5/2/17 14:09						
QC Batch No.:	170502GC8A1						
Analyst Initials:	AS						
Dilution Factor:	1.0						
ANALYTE	Result mg/L	RL mg/L					
Methane	0.42	0.0010					

ND = Not Detected (below RL)  
 RL = Reporting Limit

Reviewed/Approved By: \_\_\_\_\_

*Mark Johnson*  
 Mark Johnson  
 Operations Manager

Date

*5/4/17*

The cover letter is an integral part of this analytical report



QC Batch No.: 170502GC8A1  
Matrix: Water  
Units: mg/L

## QC for Dissolved Gases by EPA Procedure RSKSOP-175

Lab No.:		Method Blank		LCS		LCSD				
Date/Time Analyzed:		5/2/17 8:42		5/2/17 8:55		5/2/17 9:26				
Analyst Initials:		AS		AS		AS				
Datafile:		02may002		02may003		02may005				
Dilution Factor:		1.0		1.0		1.0				
ANALYTE		PQL	RL	Results	% Rec.	Criteria	% Rec.	Criteria	%RPD	Criteria
Methane		0.001	0.001	ND	104	70-130%	100	70-130%	4.0	<30

PQL = Practical Quantitation Limit

ND = Not Detected (Below RL).

RL = PQL X Dilution Factor

Reviewed/Approved By: \_\_\_\_\_

  
Mark J. Johnson  
Operations Manager

Date: \_\_\_\_\_

5/4/17

The cover letter is an integral part of this analytical report.



**AirTECHNOLOGY Laboratories, Inc.**

18501 E. Gale Avenue, Suite 130 ♦ City of Industry, CA 91748 ♦ Ph: (626) 964-4032 ♦ Fx: (626) 964-5832

$$\frac{3}{\phi}$$

1752085

*"Your Water and Wastewater Analysis Solution"*



## **APPENDIX B**

### METHANE MONITORING LOG



CITY OF LOMITA  
PUBLIC WORKS DEPARTMENT

**CYPRESS WATER PRODUCTION FACILITY  
HANDHELD METHANE LOG READINGS**

APRIL 2017					
DATE	DAY	METHANE HANDHELD			COMMENTS
4/1/2017	W	CH <sub>4</sub> -	0%	Oxy- 19.9%	
4/2/2017	TH	CH <sub>4</sub> -	0%	Oxy- 20.8%	
4/3/2017	F	CH <sub>4</sub> -	0%	Oxy- 20.3%	
4/4/2017	S	CH <sub>4</sub> -	0%	Oxy- 20.5%	
4/5/2017	SU	CH <sub>4</sub> -	0%	Oxy- 20.3%	
4/6/2017	M	CH <sub>4</sub> -	0%	Oxy- 20.1%	
4/7/2017	T	CH <sub>4</sub> -	0%	Oxy- 20.1%	
4/8/2017	W	CH <sub>4</sub> -	0%	Oxy- 20.4%	
4/9/2017	TH	CH <sub>4</sub> -	0%	Oxy- 20.5%	
4/10/2017	F	CH <sub>4</sub> -	0%	Oxy- 20.4%	
4/11/2017	S	CH <sub>4</sub> -	0%	Oxy- 19.9%	
4/12/2017	SU	CH <sub>4</sub> -	1%	Oxy- 19.9%	
4/13/2017	M	CH <sub>4</sub> -	0%	Oxy- 20.3%	
4/14/2017	T	CH <sub>4</sub> -	0%	Oxy- 20.6%	
4/15/2017	W	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/16/2017	TH	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/17/2017	F	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/18/2017	S	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/19/2017	SU	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/20/2017	M	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/21/2017	T	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/22/2017	W	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/23/2017	TH	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/24/2017	F	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/25/2017	S	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/26/2017	SU	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/27/2017	M	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/28/2017	T	CH <sub>4</sub> -	-	Oxy- -	Handheld waiting calibration
4/29/2017	W	CH <sub>4</sub> -	0%	Oxy- 19.9%	Handheld calibrated complete
4/30/2017	TH	CH <sub>4</sub> -	0%	Oxy- 20.5%	

ND- Non Detect  
CH<sub>4</sub>- Methane  
Oxy- Oxygen  
Day Off/Holiday- Red

## **APPENDIX C**

### **NITRIFICATION MONITORING DATA SUMMARY**

1 MONTHLY NITRIFICATION MONITORING SUMMARY REPORT  
CITY OF LOMITA, System No. 1910073 --- Month, Year: **April 2017**

#	Code	Sample ID	Location	Sample Date	Temp	pH	Total Chlorine	Free Chlorine	Total Ammonia	Free Ammonia	Nitrite	Nitrate	Coliform <sup>2</sup>	HPC	Zone	Comments
Units/Others →				MM/DD/YYYY	°C		mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	P/A	CFU/ml		
1	D	S13-003	1948 W 252nd St	4/5/2017	19.7	7.99	3.10	0.20	0.62	0	0.014	ND	A	ND	1	Well/MWD Blend
2	D	S13-004	24632 S Moon Ave	4/5/2017	19.6	8.07	3.20	0.11	0.68	0	0.013	ND	A	ND	1	Well/MWD Blend
3	D	S13-008	25417 Pennsylvania Ave	4/5/2017	19.8	7.99	3.50	0.10	0.68	0	0.011	ND	A	ND	1	Well/MWD Blend
4	D	A	2052 Dawn St	4/5/2017	18.8	7.71	2.50	0.19	0.60	0	0.012	ND	A	18	1	Well/MWD Blend
5	D		Reservoir	4/5/2017	19.8	7.80	3.06	0.07	0.70	0	0.000	ND	A	ND	1	Well/MWD Blend
6	D	S13-001	1912 W 259th Pl	4/5/2017	19.8	8.75	2.40	0.06	0.49	0	0.013	0.53	A	ND	2	MWD Only
7	D	S13-002	26314 S Monte Vista Ave	4/5/2017	20.5	8.65	2.40	0.03	0.44	0	0.012	0.50	A	ND	3	MWD Only
8	D	S13-005	2500 PCH	4/5/2017	19.3	8.52	2.30	0.03	0.46	0.01	0.007	0.50	A	17	2	MWD Only

  

1	D	S13-003	1948 W 252nd St	4/12/2017	18.8	7.97	3.50	0.09	0.60	0	0.012	ND	A	ND	1	Well/MWD Blend
2	D	S13-004	24632 S Moon Ave	4/12/2017	18.6	7.74	3.50	0.11	0.62	0	0.013	ND	A	ND	1	Well/MWD Blend
3	D	S13-008	25417 Pennsylvania Ave	4/12/2017	18.9	6.00	3.80	0.11	0.68	0.01	0.007	ND	A	ND	1	Well/MWD Blend
4	D	A	2052 Dawn St	4/12/2017	19.1	7.83	2.90	0.12	0.61	0	0.014	ND	A	15	1	Well/MWD Blend
5	D		Reservoir	4/12/2017	19.3	7.83	3.40	0.05	0.73	0	0.001	ND	A	ND	1	Well/MWD Blend
6	D	S13-001	1912 W 259th Pl	4/12/2017	17.6	8.61	2.40	0.07	0.48	0.02	0.015	ND	A	ND	2	MWD Only
7	D	S13-002	26314 S Monte Vista Ave	4/12/2017	17.4	8.64	2.30	0.03	0.48	0.01	0.017	0.51	A	ND	3	MWD Only
8	D	S13-005	2500 PCH	4/12/2017	17.8	8.46	2.20	0.05	0.45	0	0.010	0.51	A	ND	2	MWD Only

  

1	D	S13-003	1948 W 252nd St	4/19/2017	20.1	8.00	3.00	0.90	0.61	0	0.009	ND	A	ND	1	Well/MWD Blend
2	D	S13-004	24632 S Moon Ave	4/19/2017	19.5	7.95	3.20	0.80	0.59	0	0.012	ND	A	ND	1	Well/MWD Blend
3	D	S13-008	25417 Pennsylvania Ave	4/19/2017	20.6	7.94	3.40	0.08	0.61	0	0.008	ND	A	ND	1	Well/MWD Blend
4	D	A	2052 Dawn St	4/19/2017	20.5	7.88	2.60	0.09	0.59	0	0.012	ND	A	ND	1	Well/MWD Blend
5	D		Reservoir	4/19/2017	19.9	7.85	3.2	0.05	0.72	0.01	0.001	ND	A	ND	1	Well/MWD Blend
6	D	S13-001	1912 W 259th Pl	4/19/2017	19.5	8.55	2.20	0.50	0.42	0.01	0.013	0.54	A	ND	2	MWD Only
7	D	S13-002	26314 S Monte Vista Ave	4/19/2017	18.9	8.50	2.20	0.50	0.44	0	0.013	0.53	A	ND	3	MWD Only
8	D	S13-005	2500 PCH	4/19/2017	18.9	8.42	2.30	0.17	0.35	0	0.015	0.53	A	ND	2	MWD Only

  

1	D	S13-003	1948 W 252nd St	4/26/2017	20.6	7.59	3.10	0.06	0.6	0	0.005	ND	A	ND	1	Well/MWD Blend
2	D	S13-004	24632 S Moon Ave	4/26/2017	19.7	7.72	2.60	0.10	0.59	0.03	0.006	ND	A	ND	1	Well/MWD Blend
3	D	S13-008	25417 Pennsylvania Ave	4/26/2017	20.1	7.77	3.20	0.10	0.58	0	0.005	ND	A	ND	1	Well/MWD Blend
4	D	A	2052 Dawn St	4/26/2017	19.7	7.43	2.50	0.02	0.56	0	0.024	ND	A	8	1	Well/MWD Blend
5	D		Reservoir	4/26/2017	21.2	7.94	3.50	0.08	0.62	0	0.005	ND	A	ND	1	Well/MWD Blend
6	D	S13-001	1912 W 259th Pl	4/26/2017	18.8	8.24	2.40	0.05	0.49	0	0.003	0.54	A	ND	2	MWD Only
7	D	S13-002	26314 S Monte Vista Ave	4/26/2017	18.9	8.23	2.30	0.04	0.43	0	0.005	0.54	A	1	3	MWD Only
8	D	S13-005	2500 PCH	4/26/2017	18.7	8.20	2.30	0.13	0.46	0	0.005	0.56	A	ND	2	MWD Only

  

1	D	S13-003	1948 W 252nd St										A	ND	1	Well/MWD Blend
2	D	S13-004	24632 S Moon Ave										A	ND	1	Well/MWD Blend
3	D	S13-008	25417 Pennsylvania Ave										A	ND	1	Well/MWD Blend
4	D	A	2052 Dawn St										A	ND	1	Well/MWD Blend
5	D		Reservoir										A	ND	1	Well/MWD Blend
6	D	S13-001	1912 W 259th Pl										A	ND	2	MWD Only
7	D	S13-002	26314 S Monte Vista Ave										A	ND	3	MWD Only
8	D	S13-005	2500 PCH										A	ND	2	MWD Only

<sup>1</sup>Notes: Report Due to DDW by the 10th of the following month. This Report can be used for the routine weekly monitoring (one Report per month) as well as for daily monitoring when there is actual and potential for nitrification (about four or five Reports per month, in this case).

<sup>2</sup>Coliform results are part of weekly Bacti sampling results.